



The manufacturer
may use the mark:



Revision 2.5 April 6, 2026
Surveillance Audit Due
May 31, 2026



Certificate / Certificat Zertifikat / 合格証

VEL 1405020 C004

exida hereby confirms that the:

Coker Ball Valves

Velan

Montreal, QC - Canada

Has been assessed per the relevant requirements of:

IEC 61508 : 2010 Parts 1-2

and meets requirements providing a level of integrity to:

Systematic Capability: SC 3 (SIL 3 Capable)

Random Capability: Type A, Route 2_H Device

**PFH/PFD_{avg} and Architecture Constraints
must be verified for each application**

Safety Function:

The Valve will move to the designed safe position per the actuator design within the specified safety time.

Application Restrictions:

The unit must be properly designed into a Safety Instrumented Function per the Safety Manual requirements.



Evaluating Assessor

Certifying Assessor

VEL 1405020 C004

Systematic Capability: SC 3 (SIL 3 Capable)**Random Capability: Type A, Route 2_H Device****PFH/PFD_{avg} and Architecture Constraints
must be verified for each application****Systematic Capability :**

The product has met manufacturer design process requirements of Safety Integrity Level (SIL) 3. These are intended to achieve sufficient integrity against systematic errors of design by the manufacturer.

A Safety Instrumented Function (SIF) designed with this product must not be used at a SIL level higher than stated.

Random Capability:

The SIL limit imposed by the Architectural Constraints must be met for each element. This device meets *exida* criteria for Route 2_H.

**IEC 61508 Failure Rates in FIT¹, Coker Ball Valves, Type K,
Clean Service**

Application	λ_{SD}	λ_{SU}	λ_{DD}	λ_{DU}
Full Stroke	0	0	0	516
Tight Shut Off	0	0	0	1210
Open on Trip	0	199	0	348
Full Stroke with PVST	0	0	188	329
Tight Shut Off with PVST	0	0	188	1022
Open on Trip with PVST	199	0	188	160

¹ FIT = 1 failure / 10⁹ hours

PVST = Partial Valve Stroke Test of a final element Device

SIL Verification:

The Safety Integrity Level (SIL) of an entire Safety Instrumented Function (SIF) must be verified via a calculation of PFH/PFD_{avg} considering redundant architectures, proof test interval, proof test effectiveness, any automatic diagnostics, average repair time and the specific failure rates of all products included in the SIF. Each element must be checked to assure compliance with minimum hardware fault tolerance (HFT) requirements.

The following documents are a mandatory part of certification:

Assessment Report: VEL 14-05-020 Velan Assessment Report R003 V2R3
Safety Valves IEC 61508 Assessment (or later)

Safety Manual: SIL-CBV



80 N Main St
Sellersville, PA 18960